



Delhi Jal Board

No.DJB/QCLTYR/PD/251205

DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



NO: DJB/ACWA(TYR)/2025/795

DATE:- 20-12-2025

29-12-2025

Analysis report of DJB water supply samples collected from (1) Inlet, (2) Outlet of M/S SALWAN PUBLIC SCHOOL, KONDLI GHAROULI COMPLEX, MAYUR VIHAR PHASE-III, DELHI-110096 for drinking purpose.

Ref. No. SPS/MV/2025-2026/5841,  
Challan No: - 224,

dated: - 05.11.2025

dated: - 16.12.2025

Date of collection: 18.12.2025

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
<b>A. Physical Examination</b>						
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	CHLOR.	CHLOR.
3.	Turbidity	1.0	5.0	NTU	3.46	3.71
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	285	310
6.	Total Dissolved Solids	500	2000	mg/l	185	201
<b>B. Chemical Examination</b>						
7.	P <sup>th</sup> Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	96	96
9.	Total Hardness	200	600	mg/l	104	116
10.	Calcium as (Ca)	75	200	mg/l	31.2	38.4
11.	Magnesium as (Mg)	30	100	mg/l	6.24	4.80
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	....	....	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	7.34	5.99
15.	Sulphate	200	400	mg/l	39.95	45.56
16.	Chloride	250	1000	mg/l	12	16
17.	Fluoride	1.0	1.5	mg/l	0.06	0.06
18.	Dissolved Iron	1.0	NR	mg/l	0.14	0.18
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	1.00	0.30
<b>C. Bacteriological Examination</b>						
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheiks Lal)

ACWA(TYR)

Asstt. Chief Water Analyst

D.J.B. Govt. of N.C.T. of Delhi

Quality Control Zonal Laboratory (Tyr)  
Tahir Pur Dilshad Garden, Delhi-93

(A.G Susmitha)

BACTERIOLOGIST

(Gulesh Jainar)

CHEMIST

(Gyaneshwar Prasad)

A/CHEMIST

**MUNICIPAL CORPORATION OF DELHI**  
**Public Health Department**  
**Shahdara (South) Zone**  
**419, Udyog Sadan,**  
**Patparganj Industrial Area Delhi-110092**

No. DHO/Shah.(S)/2025/D- 1149

Dated:- 30/6/25

**School Health Certificate**

1. Name of School	: Salwan Public School
2. Location of the School	: Mayur Vihar Ph-III Kondli Gharoli, Complex New Delhi-110096
3. School timing	: 8:40AM to 02:30PM
4. No. of Students	: 1631
5. No. of Doors in each room	: Provided
6. No. of Fans in each room	: Provided
7. Building Structure	: Pucca
8. Electricity	: BSES
9. Water Supply	: DJB supply
10. No. of Urinals and WCS	: Provided
11. No. of Teaching Staff	: 63
12. No. of Tab	: Provided
13. No. of Rooms	: 74
14. No. of Bathrooms & lavatories for boys	: 64
15. No. of Bathrooms & lavatories for girls	: 42

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

*Shah*  
30/6/25

Deputy Health Officer  
Shahdara (South) Zone  
Deputy Health Officer  
Shahdara South Zone  
Municipal Corporation of Delhi

The Principal  
Salwan Public School  
Mayur Vihar Ph-III,  
Kondli Gharoli, Complex,  
New Delhi-110096

